

KEY NOTES

- 1. VERIFY WITH USER THE USE OF FO265, CHAIR, VERSES M4665, STRETCHER.
- 2. PROVIDE A1165, IV TRACKS, FOR NAVY PROJECTS ONLY.
- PROVIDE AT LEAST ONE HANDWASHING FACILITY OR ONE FOR EVERY THIRD RECOVERY MODULE.
 P3200, UITR ELECTRONIC LAVATORY, MAY BE USED INSTEAD OF P3100, LAVATORY. FOR THE P3200 PROVIDE EITHER BATTERY POWER OR HARD WIRED CONNECTION.
- 4. SIZE AND CONFIGURATION OF E0406, NURSE STATION, MAY VARY.
- 5. LENGTH OF E1500, WALL MOUNTED RAIL, TO BE DETERMINED BY MANUFACTURER/INSTALLER.
- 6. SEE ELEVATION OF A1107, UTILITY RAIL SYSTEM, FOR UTILITIES.
- 7. ALL CABINETS SHALL BE LOCKING.

RECOVERY CUBICLE, OUTPATIENT & NURSE STATION, OUTPATIENT CLINICS (RROP1/NSTA4)

